

## RISK ASSESSMENT FOR FIRE SAFETY

R.E.K. Rowlands & Partners, The Grange, Warrington Road, Mickle Trafford, Chester  
 CH2 4EB  
[www.redpollbeef.eu](http://www.redpollbeef.eu)

IN THE EVENT OF FIRE, TELEPHONE 999 AND STATE "FIRE" WHEN ASKED WHICH SERVICE YOU REQUIRE. THE ADDRESS IS ABOVE, AND THE MAIN ENTRANCE FOR EMERGENCY VEHICLES IS HALF WAY BETWEEN, AND ON THE OPPOSITE SIDE OF THE ROAD FROM, BEESLEY & FILDES (DEESIDE SAWMILLS) AND MEADOW FISHERY. THE FIRE HYDRANT IS LOCATED ON THE CHESTER (SOUTH WEST) SIDE OF THE MAIN ENTRANCE. THE FIRE ASSEMBLY POINT IS AT THE MAIN ENTRANCE. NO FERTILISER IS STORED ON THESE PREMISES.

<u>Location</u>	<u>Fire Risk level</u>	<u>Potential for Harm</u>	<u>Controls &amp; Remedial Actions</u>	<u>Outcome</u>
Old Dairy & Garage	High	High	Repair roof to ensure rainwater is kept separate from electricity. Isolate electricity at main switch when not in use.	Low.
Pump House	Low	Low	None.	Low.
Mash House	Medium	High	Provide secure battery charging facilities.	Low.
Hay Loft	High	High	Keep damp bales separate. Check at least daily for signs of smouldering.	Low.
Cubicles	Low	Low	None.	Low.
Stables	Medium	Medium	Careful storage of hay to reduce potential heat levels. Isolate electricity supply.	Low.
Dairy & Milking Parlour	Medium	Medium	This building is due to be converted to a meeting room with washing and toilet facilities, and will be rewired and fully compliant with current legislation.	Low.
Tractor Sheds	Low	Low	None.	Low.
Bay	High	Medium	Careful storage of straw to prevent spontaneous combustion. Check bales at least daily.	Low.
Joseph	Low	Low	None.	Low.

Shed				
------	--	--	--	--